

## BIDDING SPECIFICATIONS

The El Paso County Water Improvement District No.1, proposes to purchase Water Flow Meters specified in the bidding specifications.

**The Water Flow Meters must have the following Standard Features:**

- Pipe size 4", 6", 8", 10", 12"
- Saddle Mount
- 150 psi (10.3 bar) working pressure
- Plus/min 2% with default calibration, plus/min with factory calibration
- Hardware/Software, conductivity based (optional)
- 2-line LCD
- Nonvolatile memory
- Anti-reverse totalizer
- 9 digits of precision
- Flow rate & velocity (to 5 digits of precision)
- Programmed for CFS/AF
- Battery 3.6V lithium (field replaceable)
- IP68 (submersible sensor)
- Housing IP67, certified diecast aluminum, power coater (tamper resistant seal, 6.1/2" x 6-1/2" x 4-3/8tall)
- Saddle Mount (stainless steel)
- Electrodes (stainless steel)
- 5-year standard warranty

**To be delivered to EPCWID1, 13247 Alameda Ave., Clint TX 79836, if any defects or damage is found the vendor shall provide credit to our account and incur costs associated with shipment back of defective or damaged items.**

**Please complete the following:**

- 1.) Please indicate what period of time you will guarantee the prices for the Water Meters.**
- 2.) Confirm that your records/invoices provided to the El Paso County Water Improvement District No. 1, indicate the following information:**
  - 3A. Account Number**
  - 3B. Date**
  - 3C. Item Number and Description of Item**
  - 3D. Signature of Person making the transaction**
- 3.) The Proposal shall contain the Brand Name of the item being proposed, and price.**
- 4.) The Proposal shall be placed in an envelope with the name of the person, Firm, or Corporation submitting such proposal and clearly marked "Water Flow Meter". DO NOT OPEN UNTIL August 13, 2020 after 12:00 P.M.**
- 5.) Failure to comply with the proposal requirements of the El Paso County Water Improvement District No. 1, will be grounds for the rejection of bid proposal.**